

6/16/2009

VistaClear Research Group, LLC  
1554 Township Road 805  
Ashland, Ohio 44805



CITY OF DALLAS

RE: Amended approval of VistaClear Dental Waterline Treatment System

To Whom It May Concern,

In response to your request for approval of the VistaClear Dental Waterline Treatment System and Backflow Prevention, we will allow this system to be installed with a single RPZ on the water supply to the system in lieu of RPZ's on each dental chair.

**VistaClear** Dental Waterline Treatment System has been approved for use in the City of Dallas with a single RPZ backflow prevention device. The device shall be placed ahead of the inlet to the system. The system shall be installed according to manufactures installation instructions additional backflow devices will not be required other than the backflow protection supplied with this system.

Any cross contamination between the dental stations will be the responsibility of the owner and VistaClear. It will be the responsibility of VistaClear to insure that the system has been installed to the manufactures installation instructions and is functioning as designed.

When plans for use of the system are submitted to the City of Dallas for review, the use of the VistaClear system must be specified on the submittal. This approval letter supersedes any previous approvals or disapprovals.

Best Regards,

Lonnie Erwin  
Lonnie Erwin  
Chief Plumbing and Mechanical Inspector  
Development Services  
Building Inspection  
City of Dallas