

CITY OF LOS ANGELES
CALIFORNIA

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

VAN AMBATIELOS
PRESIDENT

E. FELICIA BRANNON
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL
GEORGE HOVAGUIMIAN
JAVIER NUNEZ



ERIC GARCETTI
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

FRANK M. BUSH
GENERAL MANAGER
SUPERINTENDENT OF BUILDING

OSAMA YOUNAN, P.E.
EXECUTIVE OFFICER

James Chandler
Vista Research Group, Llc
1554 Township Road 805
Ashland, OH 44805

Telephone: 419-281-3927

Models:

SINGLE OPERATORY: 1000 | CENTRAL SYSTEM: 1000-(23, 34, 46 & 47)-C; 1000-28-HP

File Number: M-040014

Effective Date: 07/01/2018

Expiration Date: 07/01/2019

Manufacturer: VISTA RESEARCH GROUP

Item: DENTAL WATERLINE FILTER

PLEASE REFER TO THE APPLICATION NUMBER ON ALL CORRESPONDENCE, PHONE CALLS & SAMPLES

The item processed under the above file number has been tested, examined and found to comply with applicable Los Angeles Plumbing Code (LAPC) and/or Los Angeles Mechanical Code (LAMC) and is hereby approved unless revoked for cause.

This letter or the letterhead copy may not be reproduced for use in labeling or advertising, but copies of this letter may be used within your organization and shown as evidence of approval.

CONDITIONS OF APPROVAL:

- 1. An approved spring-loaded double check valve shall be installed on each water inlet to the filter per Section 94.603 of the LAPC, 2017 Edition.**
- 2. The drain line shall be routed without dips and sags into an indirect waste receptor 1" or two pipe size, whichever is greater, above its flood level per Section 94.801 of the LAPC, 2017 Edition.**
- 3. This product shall be installed, operated, and maintained in accordance with instructions from the manufacturer and LAPC, 2017 Edition.**

Each item shall have the name or trademark of manufacturer and model number where it will be visible for inspection.

In order to renew this approval, an application and reexamination fee must be submitted on or before the expiration date shown above. Arrangement shall be made to remove any test samples remaining in the Laboratory. Samples remaining after 21 days from the date of this notice will be shipped collect by the most convenient carrier or disposed of in accordance with applicable regulation.

Irene M Pool Tamayo
Mechanical Testing Laboratory, Test Engineer