

DT: July 7, 2007

TO: All Vista Research Group Customers, Contractors and Inspectors

FR: Jim Chandler

RE: **State of Oregon – Product Approvals**

This letter can be used to provide backflow prevention approval information from the State of Oregon for our products. I've been in contact with Mr. Terry Swisher, Chief Plumbing Inspector, regarding OR State approvals. He indicated that their office does not provide "approval" letters for individual products but that I should communicate this information to you for use by dental dealers, general contractors, plumbing contractors and local inspectors.

The following summarizes the backflow installation requirements for Vista Research Group, LLC products:

1. *VistaClear* Dental Waterline Treatment Systems

The *VistaClear* water systems are approved for use, but since the *VistaClear* system can be connected directly to multiple dental chairs, the main water supply to it is required to be equipped with a R.P. device. Each *VistaClear* has internal backflow protection and individual R.P. devices are not required and should not be used on each individual operatory line after the *VistaClear*. Systems should be installed according to manufacturer's instructions.

2. *VistaPure* Ultra Pure Water Systems

The *VistaPure* water systems are approved for use. No R.P. device is required since *VistaPure* systems have a pressurized drain, internal backflow protection, discharge lines are not used on or near dental patients and are designed to produce ultra pure water with a TDS of near 000 mg/l. Water stored in the pressure tank is vastly higher in quality than the municipal water and presents no aesthetic or health hazard.

If you or anyone involved with our products have questions or need clarification, contact me at the number below or Terry Swisher at 503-373-7488.

"OR – Approvals"